



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 3

### General Comments

Inspection satisfactory.

Email Address(es): lewistraceyn@dadeschools.net;  
mcgarcia@dadeschools.net;  
wcabrera@dadeschools.net;  
mwertz@dadeschools.net;  
ipalacio@dadeschools.net;  
miriamg@dadeschools.net

### Violations Comments

#### Violation #3. Athletic & Playground Equipment

At the time of inspection at playground area padded floors with signs of wearing a tear (no trip hazard). Repair playground floors.

CODE REFERENCE: 3. Athletic and Playground Equipment. 5(2)(k)4 SREF. Athletic and playground equipment, where provided, shall be structurally sound, maintained firm and stable, vermin-proof, free of pockets or crevices where water will collect or vermin and pests may hide, and free from jagged or sharp projections, edges, or corners. Playground equipment includes the equipment itself (backstops, swings, slides, etc.) and its structural components (foundations, supporting members, exposed fasteners, etc.).

#### Violation #5. Maintenance & Repair

At the time of inspection observed in classroom #32, AC unit not working (no students occupation the classroom). Repair or replace the AC unit.

At the time of inspection observed in classroom #34 one light out (55 fc). Replace light.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

#### Violation #12. Toilet Facilities

At the time of inspection at boy's restroom #055 one tile wall missing (4"x4"). Provide wall tile.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

#### Violation #18. Drinking Fountains

At the time of inspection observed outside classroom #047 water fountain out of service. Repair or replace water fountain.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



3 of 3

Inspection Conducted By: Alexander Olaya (67699)  
Inspector Contact Number: Work: (305) 623-3500 ex.  
Print Client Name: Maria Fernandez  
Date: 4/8/2026

Inspector Signature:

A handwritten signature in black ink, appearing to be "Alexander Olaya".

Client Signature:

A handwritten signature in black ink, appearing to be "Maria F".